



### CROSSING SECTION

#### NOTES:

1. IF WATERMAIN IS LESS THAN 18" ABOVE SANITARY OR STORM SEWER, REUSE OR SEWERAGE FORCEMAIN PIPE AT A CROSSING, THEN CENTER ONE FULL LENGTH JOINT OF D.I.P. ON CROSSING POINT.
2. ALL PIPING CLEARANCES SHALL BE IN ACCORDANCE WITH CHAPTER 62-555.314, F.A.C.
3. DO NOT ENCASE PIPING IN CONCRETE UNLESS SPECIFICALLY AUTHORIZED.
4. ALL PIPING SHALL CLEAR OTHER CONSTRUCTION BY 6" MINIMUM.

## **PIPING CLEARANCES**

NOT TO SCALE



## **City of Leesburg Standard Details**



**FARNER  
BARLEY**

AND ASSOCIATES, INC.  
350 North Sholar Avenue, O Tavares, Florida 32778 ☎ (352) 343-8481

▲ ENGINEERS  
▲ SURVEYORS  
▲ PLANNERS

**April 2004**

**Detail G-4**